



Public Protection Cabinet
 Department of Housing Buildings and Construction
 Division of Plumbing
 500 Mero St, 1st Fl
 Frankfort, KY 40601
 502-573-0397

Water Service Installation Virtual Inspection Checklist

General Information:

Journeyman plumbers signature:	_____
Journeyman license number:	J _____
Date of test:	_____
Permit number:	_____
Address of installation:	_____
Type of construction:	Single Family: ___ Multi Family: ___ Commercial: ___

Installation Location:

Specific location where installed on property:	Front left: ___ Front center: ___ Front right: ___ Rear left: ___ Rear center: ___ Rear right: ___ Other location info: _____ _____
--	--

Installation Material:

Type of material used: Specific material used: (PEX, Copper K, SDR 21 PVC, or PE)	Copper: ___ CPVC: ___ PEX: ___ PVC: ___ PE: ___ Other: ___ (Other material type) _____
Minimum eighteen (18) AWG copper tracer wire installed: Ending point of tracer wire:	Yes: ___ No: ___ Meter vault: ___ Above foundation: ___

Depth of Installation:

Confirmed water service is thirty (30) inches deep:	Yes: ___ No: ___
---	------------------

Benching or Shelving Installation:

Five (5) foot separation from sewer	Yes: ___ No: ___
water service / sewer same ditch:	Yes: ___ No: ___
Same ditch installation:	Yes: ___ No: ___
Eighteen (18) inches above the top of sewer	
Water service placed on solid shelf:	Yes: ___ No: ___
Joints kept to a minimum:	Yes: ___ No: ___

Protection of Water Service:

Properly sleeved or protected water service: (Example: Crossed sewer or rocks in spoils)	Yes: ___ No: ___
Sleeve made of proper water service material:	Yes: ___ No: ___
Sleeve sealed on each end:	Yes: ___ No: ___
No physical connection between public and private water:	Yes: ___ No: ___